

Available Generation by Feeder per O. Reg 326/09 - June 30, 2016

| Station | Feeder Designation | Voltage (Volts) | Load (MVA) | | Minimum Available Fault | | Maximum Available Fault | | Available Capacity to Connect Generation (kVA) | | Capacity Restrictions Exist |
|----------------------|--------------------|-----------------|-------------------|-------------------|-------------------------|-------------|-------------------------|-------------|--|---------------------------------|-----------------------------|
| | | | Minimum | Maximum | Ph-G Amps | 3 Ph SCMVA | Ph-G Amps | 3 Ph SCMVA | Capacity Allocation Required | No Capacity Allocation Required | |
| RH Martindale | 9M1 | 44,000 | 8.6 | 25.7 | 693 | 9090 | 1108 | 15589 | 5976 | 500 | 0 |
| | 9M2 | 44,000 | 8.6 | 25.7 | 693 | 9090 | 1108 | 15589 | 9108 | 500 | 0 |
| | 9M3 | 44,000 | 8.6 | 25.7 | 693 | 9090 | 1108 | 15589 | 6985 | 500 | 0 |
| | 9M4 | 44,000 | 8.6 | 25.7 | 693 | 9090 | 1108 | 15589 | 2914 | 500 | 0 |
| Hydro One Feeder | 9M5 | 44,000 | N/A | N/A | 693 | 9090 | 1108 | 15589 | Contact Hydro One | 500 | 0 |
| Hydro One Feeder | 9M6 | 44,000 | N/A | N/A | 693 | 9090 | 1108 | 15589 | Contact Hydro One | 500 | 0 |
| Hydro One Feeder | 9M7 | 44,000 | N/A | N/A | 693 | 9090 | 1108 | 15589 | Contact Hydro One | 500 | 0 |
| Clarabelle | 28M4 | 44,000 | 8.6 | 25.7 | 677 | 8887 | 1129 | 14814 | 4777 | 500 | 0 |
| | 28M5 | 44,000 | 8.6 | 25.7 | 677 | 8887 | 1129 | 14814 | 5398 | 500 | 0 |
| | 28M6 | 44,000 | 8.6 | 25.7 | 677 | 8887 | 1129 | 14814 | 7120 | 500 | 0 |
| Coniston | 1M1 | 22,000 | unavailable | unavailable | unavailable | unavailable | unavailable | unavailable | 0 | 0 | 1 |
| Crystal Falls | 7M1 | 44,000 | Contact Hydro One | Contact Hydro One | 257 | 3366 | 539 | 7066 | Contact Hydro One | 500 | 0 |
| | 7M2 | 44,000 | Contact Hydro One | Contact Hydro One | 257 | 3366 | 539 | 7066 | Contact Hydro One | 500 | 0 |