

Available Generation by Feeder per O. Reg 326/09 - Feb 17, 2017

Station	Feeder Designation	Voltage (Volts)	Load (MVA)		Minimum Available Fault		Maximum Available Fault		Available Capacity to Connect Generation (kVA)		Capacity Restrictions Exist	
			Minimum	Maximum	Ph-G Amps	3 Ph SCMVA	Ph-G Amps	3 Ph SCMVA	Capacity Allocation Required	No Capacity Allocation Required		
RH Martindale	9M1	44,000	8.6	25.7	693	9090	1108	15589	4713	500	0	
	9M2	44,000	8.6	25.7	693	9090	1108	15589	6618	500	0	
	9M3	44,000	8.6	25.7	693	9090	1108	15589	447	500	0	
	9M4	44,000	8.6	25.7	693	9090	1108	15589	5660	500	0	
	Hydro One Feeder	9M5	44,000	N/A	N/A	693	9090	1108	15589	Contact Hydro One	500	0
	Hydro One Feeder	9M6	44,000	N/A	N/A	693	9090	1108	15589	Contact Hydro One	500	0
	Hydro One Feeder	9M7	44,000	N/A	N/A	693	9090	1108	15589	Contact Hydro One	500	0
Clarabelle	28M4	44,000	8.6	25.7	677	8887	1129	14814	4821	500	0	
	28M5	44,000	8.6	25.7	677	8887	1129	14814	3203	500	0	
	28M6	44,000	8.6	25.7	677	8887	1129	14814	7130	500	0	
Coniston	1M1	22,000	unavailable	unavailable	unavailable	unavailable	unavailable	unavailable	0	0	1	
Crystal Falls	7M1	44,000	Contact Hydro One	Contact Hydro One	257	3366	539	7066	Contact Hydro One	500	0	
	7M2	44,000	Contact Hydro One	Contact Hydro One	257	3366	539	7066	Contact Hydro One	500	0	